



# CITY OF LA CROSSE UTILITIES

WATER • SEWER • STORM

400 La Crosse Street

La Crosse, WI 54601

In Partnership with HydroCorp

## Inspection Non-Compliance Notice 1

Print Date: 08/31/2015

CUSTOMER NAME  
MAILING ADDRESS  
La Crosse, WI 54601

## SAMPLE NON-RESIDENTIAL NON-COMPLIANCE NOTICE

**RE:** CUSTOMER NAME at SERVICE ADDRESS

The purpose of the **La Crosse Water Utility** Cross Connection Control Program, as defined in the local Cross Connection Ordinance, is to help eliminate possible contamination of the public water distribution system.

The Wisconsin Department of Natural Resources requires a survey of every facility connected to the public water supply. We are working with HydroCorp to conduct these surveys.

An inspection of your facility's internal water distribution system was completed on **Aug 26 2015**. Inspectors reviewing your water system found connections that could possibly contaminate the public water distribution system. A list of requirements is enclosed.

</> Requirements on this list must be addressed using only State approved backflow prevention devices. A licensed plumber should be able to assist you with acquiring approved backflow prevention devices. Some backflow prevention devices (assemblies) also require testing by a State Certified Tester. We suggest that the licensed plumber installing the testable assemblies also have the state certification to test assemblies. ***All testable assemblies must be tested immediately at the time of installation.***

These requirements must be completed by **09/30/2015**. Once the requirements(s) have been corrected, please contact the City of La Crosse Water Utility at 608-789-7536 or visit [www.hydrocorpinc.com/lacrosse](http://www.hydrocorpinc.com/lacrosse) to schedule a compliance inspection. If you are unable to complete the work in this time, please contact HydroCorp to discuss an extension.

If you have any questions please contact the City of La Crosse Water Utility at 608-789-7536 or HydroCorp at **800-690-6651 Ext. 5019**. Thank you in advance for your cooperation.

Order #	Device Type	Comment
61	Other	Install a wasting on slop sink in janitorial closet room 102
62	VDCV	Install vented dual check valve ASSE (1012) in water supply to combi ovens
63	SVB	Install a spill resistant vacuum breaker ASSE (1056) on water supply to hose bib for combi oven